



This document, together with the concepts and designs presented herein, are an instrument of service, prepared only for the specific project and client for which it was prepared. Review of and proper reliance on this document without written authorization and objection by Kinley-Horn and Associates, Inc. shall be without liability to Kinley-Horn and Associates, Inc.



1 DRIP LOOP DETAIL
E7 NOT TO SCALE



2 TYPICAL TRENCH DETAIL
E7 NOT TO SCALE

- NOTES:
1. GROUND SURFACE IS OTHER THAN NEWLY GRAVELED AREA. CONTRACTOR IS TO RESTORE TO ORIGINAL CONDITION.
 2. PROVIDE PVC CONDUIT BELOW GRADE EXCEPT AS NOTED BELOW.
 3. PROVIDE SCHEDULE 40 OR SCHEDULE 80 PVC CONDUIT & ELBOWS AT STUB UP LOCATIONS (I.E. POLES, EQUIPMENT, ETC.)
 4. PROVIDE SCHEDULE 80 PVC CONDUIT BELOW PARKING LOTS AND ROADWAYS.



1000 LANTANA DRIVE, SUITE 2000
ANN ARBOR, MI 48106

PROJECT INFORMATION:

SITE NAME:
OLD STATE ROAD
SITE NO.: 502591
FUZE PROJECT#: 15525785
GOOD HOPE BRIDGE
NANKIN, GA 31824
LUMINIS GRANITE

PLANS PREPARED BY:

Kimley-Horn
11720 AMBER PARK DRIVE, SUITE 600
ALPHARETTA, GA 30209
WWW.KH.COM
WWW.KH.COM

| REV# | DATE | ISSUED FOR | BY |
|------|----------|--------------|-----|
| 7 | | | |
| 6 | | | |
| 5 | | | |
| 4 | | | |
| 3 | | | |
| 2 | | | |
| 1 | | | |
| 0 | 05/16/20 | CONSTRUCTION | CCH |
| A | 05/12/20 | PRELIMINARY | CCH |

LICENSE#:
TIM MERCHANT
ELECTRICAL ENGINEER
NO. 10000
CORBIN C. HIRD
ELECTRICAL ENGINEER
NO. 10000
L 12/20

KHA PROJECT NUMBER:
013509094
DRAWN BY: WCE
CHECKED BY: WCE
SHEET TITLE:
ELECTRICAL
DETAILS
SHEET NUMBER:
E7