

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: UPS Replacement at the Valdosta and Clyattville Public
Safety Radio System Tower Sites

DATE OF MEETING: November 12, 2024

Work
Session/Regular
Session

BUDGET IMPACT: Valdosta UPS Replacement Cost: \$ 27,051.56
Clyattville UPS Replacement Cost: \$27,051.56
Cowart Electric Installation Cost: \$18,000

Total : \$72,103.12

FUNDING SOURCE:

- Annual
- Capital
- N/A
- SPLOST
- TSPLOST

COUNTY ACTION REQUESTED ON: UPS Replacement at the Valdosta and Clyattville Public
Safety Radio System Tower Sites

HISTORY, FACTS AND ISSUES: This is a budgeted item for the replacement of the current Uninterruptible Power Supply (UPS) units located at the Valdosta and Clyattville Public Safety Radio System Tower Sites. The current units at the tower sites are reaching their end of life and soon will not be supported. The current UPS at the Valdosta tower was installed on 9/13/2002 (22 years old). The current UPS at the Clyattville tower was installed on 10/31/2002 (22 years old).

OPTIONS: 1. Approve
2. Board's Pleasure

RECOMMENDED ACTION: Approve

DEPARTMENT: E911

DEPARTMENT HEAD: Tonya Davis

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: