

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Union Road Lift Station Pump Replacement

DATE OF MEETING: January 14, 2025

Work
Session/Regular
Session

BUDGET IMPACT: \$51,196.00

FUNDING SOURCE:

- Annual
- Capital
- N/A
- SPLOST
- TSPLOST

COUNTY ACTION REQUESTED ON: Union Road Lift Station Pump Replacement.

HISTORY, FACTS AND ISSUES: The Union Road Lift Station is on the north end of the county serving Creekside West and Frank's Creek subdivisions. This is a duplex station with 45hp pumps. One of the pumps is in need of major repairs. The pump was pulled and sent to Xylem for repairs. After break down and evaluation the repair quote is \$45,761.60. The quote for a new replacement pump is \$51,196.00. Staff recommends approval to purchase the new replacement pump from Xylem for \$51,196.00.

OPTIONS: 1. Approve
2. Board's Pleasure

RECOMMENDED ACTION: Approve

DEPARTMENT: Utilities

DEPARTMENT HEAD: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: