## LOWNDES COUNTY BOARD OF COMMISSIONERS COMMISSION AGENDA ITEM

SUBJECT: Whitewater Road Lift Station Pump	
	Work
DATE OF MEETING: February 11, 2025	Session/Regular
	Session
BUDGET IMPACT: \$46,446.52	
FUNDING SOURCE:	
(X) Annual	
( ) Capital	
( ) N/A	
( ) SPLOST	
( ) TSPLOST	

COUNTY ACTION REQUESTED ON: Whitewater Road Lift Station Pump

HISTORY, FACTS AND ISSUES: The Whitewater Road lift station is a triplex station on our trunk line leading to the LAS. One of the older pumps is out of service. The pump was sent to Xylem and the cost of repairs is over 75% of the cost of a new pump. The new pump comes with a N-impeller which is on the other pumps and significantly helps with clogging. Staff recommends purchasing a new pump for \$46,446.52 from Xylem, Inc.

OPTIONS: 1. Approve

2. Board's Pleasure

**RECOMMENDED ACTION: Approve** 

DEPARTMENT: Utilities DEPARTMENT HEAD: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: