

Staff was able to procure two quotes from pre-engineered metal building companies to repair the buildings. Superior Metal Buildings in the amount of \$59,369.34 and Gary Weaver Construction in the amount of \$62,280.00. Mr. McLeod stated this project is being completed under the emergency purchases' policy.

Alapaha Plantation Water Treatment Plant New Wells & Water Main Extension

Utilities Director, Steve Stalvey presented the item. Mr. Stalvey stated Alapaha Plantation water system continues to experience issues with disinfection by-products and is currently under a consent order with the Georgia Environmental Protection Division (EPD). County staff has worked closely with Lovell Engineering, TTL geologist and Georgia EPD have determined the need to drill two new supply wells to provide water to Alapaha Plantation, running a water main to the existing water treatment plant and an additional 20,000gallon storage tank. Mr. Stalvey stated three bids were received with Standard Contractors submitting the low bid, in the amount of \$1,711,265.60. Additionally, Mr. Stalvey stated that once this project is completed, a test will be run on the system. Chairman Slaughter asked how deep these wells would be dug, will they be in the Florida aquifer, Mr. Stalvey answered yes, the design is to drill approximately six hundred feet. Commissioner Wisenbaker asked the size of the well, Mr. Stalvey answered a six inch well. Commissioner Smith asked when this project will go online, Mr. Stalvey answered in the late summer or early fall time frame.

REPORTS - County Manager

There was no additional information reported.

ADJOURNMENT

Commissioner Orenstein made a motion to adjourn the meeting, second by Commissioner Wisenbaker. Chairman Slaughter adjourned the meeting at 8:47 a.m.